



KOPOS KOLÍN a.s.
Havlíčková 432
CZ – 280 94 Kolín IV

EU DECLARATION OF CONFORMITY No. 1A-EU-01/20-03

In accordance with EU directive 2014/35/EU as amended

We, KOPOS KOLÍN a. s.
Havlíčková 432
280 94 Kolín IV
Czech Republic
IČ: 61672971
DIČ: CZ61672971

declare under our sole responsibility that

the product/type: **Electroinstallation boxes for mounting under plaster and accessories**

manufacturer: **KOPOS KOLÍN a.s. Havlíčkova 432, 280 94 Kolín IV, Czech Republic**

object of the declaration: Boxes and covers used for electric accessories for house and other similar fixed electrical installations.
Temperature resistance of the boxes is -5 °C to + 60 °C.
Protection against solid objects IP 30 is fulfilled if accessories with protection IP 30 or higher are used. The needle burner test was conducted in accordance with ČSN EN 60695-11-5 with satisfactory result.
Passing the glow-wire test at temperature 850°C.

Halogen free boxes don't contain halogens. They are in an environment with higher concern over public and health protection and are marked with the HF letters at the end of the model number.
Temperature resistance of the boxes halogen free is -20 °C to + 80 °C.
Protection against solid objects IP 30 is fulfilled if accessories with protection IP 30 or higher are used.
Passing the glow-wire test at temperature 850°C. . The needle burner test was conducted in accordance with ČSN EN 60695-11-5 with satisfactory result.

The object of the declaration described above is in conformity with the relevant Union harmonisation legislation, other legislation and regulations:

Regulations Of the European Union	Government Regulations	Standards	Certificates and Test Reports	Other technical specification
2014/35/EU - LVD	Law No. 90/2016 Coll. as amended Government Regulation No. 118/2016 Coll. as amended	ČSN EN 60670-1:05 including amendments (EN 60670-1:05 including amendments) ČSN EN 60670-22:07 including amendments (EN 60670-22:06 including amendments)	Test Report No. 913245-01/01 of 30.1.2020 Issued by: Elektrotechnický zkušební ústav, Pod Lisem 129, 171 02 Praha 71, Czech Republic	Halogen-free boxes
2014/35/EU - LVD	Law No. 90/2016 Coll. as amended Government Regulation No.	ČSN EN 60670-1:05 including amendments (EN 60670-1:05 including amendments)	Test Report No. 603370-01/01 of 9.12.2019 Issued by:	



KOPOS KOLÍN a.s.
Havlíčková 432
CZ – 280 94 Kolín IV

	118/2016 Coll. as amended	ČSN EN 60670-22:07 including amendments (EN 60670-22:06 including amendments)	Elektrotechnický zkušební ústav, Pod Lisem 129, 171 02 Praha 71, Czech Republic	
2014/35/EU - LVD	Law No. 90/2016 Coll. as amended Government Regulation No. 118/2016 Coll. as amended	ČSN EN 60670-1:05 including amendments (EN 60670-1:05 including amendments) ČSN EN 60670-22:07 including amendments (EN 60670-22:06 including amendments)	Test Report No. 911221-01/01 of 12.7.2019 Issued by: Elektrotechnický zkušební ústav, Pod Lisem 129, 171 02 Praha 71, Czech Republic	Testing of ESC branded products – KO 100
			Test Report No. 801482-01/01 of 26.4.2018 Issued by: Elektrotechnický zkušební ústav, Pod Lisem 129, 171 02 Praha 71, Czech Republic	Testing of ESC branded products – KP 68
Regulation 1907/2006 - REACH				Safety data sheets for used materials

By fulfilling the conditions in accordance with these regulations was placed on the product CE marking.

Conformity assessment module: **MODUL A: Internal production control**

Technical documentation of products:

- assembly instructions
- Datasheet
- Catalog for products freely available on <http://www.kopos.cz/cs/katalogy>
- Internal documents

KOPOS KOLÍN a.s. company is certificated according to the standard ISO 9001:2015, ISO 14001:2015 and ISO 50001:2011 and according to the National program „Safety Enterprise“.

Signed for KOPOS KOLÍN a.s.

Place of issue: Kolín, Czech Republic

Date of issue: 18.3.2020

Ing. Jana Dejmková

Management representative for QMS

KOPOS KOLÍN a.s.
ÚSEK ŘÍZENÍ SYSTÉMU JAKOSTI



KOPOS KOLÍN a.s.
Havlíčková 432
CZ – 280 94 Kolín IV

Enclosure No. 1 to EU Conformity Declaration No. 1A-EU-01/20-03
Wiring boxes for mouting under plaster

Boxes	Type	Rating
	KU 68	
	KU 68/1	400 V, 16 A
	KU 68-1901	400 V, 16 A
	KU 68-1902	400 V, 16 A
	KU 68-1903	400 V, 16 A
	KU 68/71 - 1	400 V, 16 A
	KU 68/71 - 2	400 V, 16 A
	KU 68/71 - 3	400 V, 16 A
	KP 67/1	500 V
	KP 67/2	500 V
	KP 67/3	500 V
	KJ	
	KP 68	
	KP 68/2	500 V
	KP 21	500 V
	KP 67x67	500 V
	KP 64/2	400 V, 16 A
	KP 64/3	400 V, 16 A
	KP 64/4	400 V, 16 A
	KP 64/5	400 V, 16 A
	KP 64/LE	400 V, 16 A
	KO 97	500 V
	KR 97	500 V
	KP 45	400V, 16A
	KO 97/5	500 V
	KR 97/5	500 V
	KR 35	400 V, 16 A
	KO 100	500 V
	KO 100 E	500 V
	KO 125	500 V
	KO 125 E	500 V
	KO 125/1	500 V
	KR 100	500 V
	KR 100/1	500 V
	KR 100/2	500 V
	KR 125	500 V
	KR 125/1	500 V
	KR 125/2	500 V
	KUH 1	400V, 16A



KOPOS KOLÍN a.s.
Havlíčková 432
CZ – 280 94 Kolín IV

Wiring box with cover

B 17 230V, IP 20 single-purpose

Type	Rating
KT 250	500V
KT 250/1	500V
KT 250x110	500V, IP 30
KT 250/2	500V

Instrument box

KPR 68
KPR 68/71
KPM 64
KOM 97

Accessories

Covers

KO 68
V 68
V 68 S
V 68 V HB
KO 97 V
KO 97 V/1
KT 250V
KO 100V
KO 125V
V 100 E
V 125 E
V 125/1
ZV 68
ZV 97
V 35
V 45

Frame

NR 68/6
NR 68/10
NR 5x5

Terminal

S - 66
S - 96
SP - 96

Distance bar

DR 18

Distance frame

DR 42

Blind cover

ZV 68/D
ZV 68 (material PE)
ZV 97 (material PE)

Thorn extension

TN 68
TN 97



KOPOS KOLÍN a.s.
Havlíčková 432
CZ – 280 94 Kolín IV

Wiring boxes for mouting under plaster - halogen free (HF)

Boxes

Type	Rating
KU 68 HF	
KU 68/1 HF	400 V, 16 A
KU 68-1901 HF	400 V, 16 A
KU 68-1902 HF	400 V, 16 A
KU 68-1903 HF	400 V, 16 A
KU 68/71 - 1 HF	400 V, 16 A
KU 68/71 - 2 HF	400 V, 16 A
KU 68/71 - 3 HF	400 V, 16 A
KP 68 HF	
KP 67/1 HF	500 V
KP 67/2 HF	500 V
KP 67/3 HF	500 V
KJ HF	400 V, 16 A
KP 68/2 HF	500 V
KP 21 HF	500 V
KP 67x67 HF	500 V
KP 64/LE HF	400 V, 16A
KP 64/2 HF	400 V, 16 A
KP 64/3 HF	400 V, 16 A
KP 64/4 HF	400 V, 16 A
KP 64/5 HF	400 V, 16 A
KO 97 HF	500 V
KR 97 HF	500 V
KO 97/5 HF	500 V
KR 97/5 HF	500 V
KUH 1	400V, 16A

Wiring box

B 17 HF 230 V, IP 20 single-purpose

Type	Rating
KT 250 HF	500V
KT 250/1 HF	500V
KT 250x110 HF	500V, IP 30
KT 250/2 HF	500V



KOPOS KOLÍN a.s.
Havlíčková 432
CZ – 280 94 Kolín IV

Instrument box

Type	Rating	
KPR	68 HF	
KPR 68/71 HF	400 V, 16 A	
KPM 64 HF	400 V, 16 A	without mounting ring
KOM 97 HF	400V, 16A	without mounting ring

Accessories

Covers

KO 68 HF
V 68 HF
V 68 S HF
V 68 S HB HF
KO 97 V HF
KO 97 V/1 HF
KT 250 V HF
KO 100 V HF
KO 125 V HF
V 100 E HF
V 125 E HF
V 125/1 HF
ZV 68 HF
ZV 97 HF
V 35 HF
V 45 HF

Terminal

S - 66
S-96
SP -96

Distance bar

DR 18 HF

Distance frame

DR 42 HF

Frame

NR 68/6 HF
NR 68/10 HF
NR 5x5

KOPOS KOLÍN a.s.
ÚSEK ŘÍZENÍ SYSTÉMU JAKOSTI